

EG-Baumusterprüfbescheinigung

EC type examination certificate

CE-0085BM0065

Produkt-Identnummer
product identification no.

Anwendungsbereich <i>field of application</i>	EG-Gasgeräte-Richtlinie (90/396/EWG) <i>EC Gas Appliances Directive (90/396/EEC)</i>
Zertifikatinhaber <i>owner of certificate</i>	ROTEX Heating Systems GmbH Langwiesenstraße 10, D-74363 Güglingen
Vertreiber <i>distributor</i>	ROTEX Heating Systems GmbH Langwiesenstraße 10, D-74363 Güglingen
Produktart <i>product category</i>	Boilers with flue systems: Condensing combi water heater (3204)
Produktbezeichnung <i>product description</i>	Condensing combi water heater with integrated water storage, forced draught burner, pneumatic air/gas regulation, automatic burner control and connection for a thermic solar unit
Modell <i>model</i>	GSU...; GCU...; GHU...
Bestimmungsländer <i>countries of destination</i>	AT, BE, CH, DE, DK, ES, FI, FR, GB, GR, HU, IE, IT, LU, NL, NO, PL, PT, SE
Prüfberichte <i>test reports</i>	supplement test: 07/247/3204/867 from 30.08.2007 (EBI)
Prüfgrundlagen <i>basis of type examination</i>	EU/90/396/EWG (29.06.1990) DIN EN 483 (01.06.2000) DIN EN 625 (01.10.1995) DIN EN 677 (01.08.1998)
Aktenzeichen <i>file number</i>	07-0301-GER

03.12.2007 Rie A-1/2

Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle
date, issued by, sheet, head of certification body

DVGW CERT GmbH - von der Deutschen Bundesregierung benannte und von der Europäischen Kommission offiziell registrierte Stelle für die Konformitätsbewertung von Gasgeräten

DVGW CERT GmbH - notified by the government of the Federal Republic of Germany and officially registered by the European Commission for conformity assessment of gas appliances



ZLS-ZE-527/07

DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 Bonn

Telefon: +49 228 91 88-888
Telefax: +49 228 91 88-993
eMail: info@dvgw-cert.com

Elektrische Daten: 230 V AC, 50 Hz, IP20
electrical data

Geräte Kategorien <i>appliance categories</i>	Versorgungsdrücke <i>supply pressures</i>	Bestimmungsländer <i>countries of destination</i>	Bemerkungen <i>remarks</i>
I2E	20 mbar	LU, PL	
I2ELL	20 mbar	DE	
I2Esi	20/25 mbar	FR	
I2H	20 mbar	AT, CH, DK, ES, FI, GB, GR, IE, IT, NO, PT, SE	
I2H	25 mbar	HU	
I2L	25 mbar	NL	
I3+	28-30/37 mbar	CH, ES, GB, GR, IE, IT, PT	
I3B/P	28-30/30 mbar	DK, FI, NL, NO, SE	
I3B/P	30 mbar	HU	
I3B/P	37 mbar	PL	
I3B/P	50 mbar	AT, CH, DE, LU	
I3P	37 mbar	BE, FR	
I12E(S)B3P	20/25, 37 mbar	BE	

Typ <i>type</i>	Technische Daten <i>technical data</i>	Bemerkungen <i>remarks</i>
GSU 528	heat output: Erdgas:4,9...26,2 kW; Flüssiggas:5,9...26,2 kW heat input - natural gas (Hi): 5,0...27,0 kW heat input - LPG (Hi): 6,0...27,0 kW	
GSU 25; GCU 25	heat output: 5,4...25,0 kW nominal heat input (Hi): 5,5...25,5 kW	
GSU 35; GCU 35	heat output: 8,0...35,0 kW nominal heat input (Hi): 8,5...36,1 kW	
GSU 320S; GSU 520S	heat output: Erdgas: 2,5...20,0 kW; Flüssiggas: 4,7...20,0 kW heat input - natural gas (Hi): 2,6...21,0 kW heat input - LPG (Hi): 4,8...21,0 (I3P) bzw. 5,4...21,0 (I3B) kW	
GSU 530S	heat output: Erdgas: 4,2...30,0 kW; Flüssiggas: 5,4...30,0 kW heat input - natural gas (Hi): 4,3...31,0 kW heat input - LPG (Hi): 5,5...31,0 (I3P) bzw. 7,5...31,0 (I3B) kW	
GSU 535; GHU 35	heat output: Ergas: 4,5...35,0; Flüssiggas: 7,0...35,0 kW heat input - natural gas (Hi): 4,6...36,1 kW heat input - LPG (Hi): 7,1...34,1 (I3P) bzw. 7,8...36,1 (I3B) kW	

Ausführungsvariante <i>type variation</i>	Erläuterungen <i>explanations</i>
GSU...	with solar unit connection
GCU...; GHU	without solar unit connection
GSU 320S	storage: 300 l
GSU 520S	storage: 500 l

Verwendungshinweise / Bemerkungen *hints of utilization / remarks*

The gas appliance is certified together with the listed flue system on this EC-type registration as a system according to the Gas Appliance Directive.
 Appliance type: B23, C43, C43x, C63, C63x: according to the "Installation- and Service-Guide for installers", no. 008.1501349 and no. 008.1507649

